IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hugh Dalton DATE _____ PERMIT NO. _____

PHONE: Business _____ Home 528-1555

LOCATION 150 ft on 115 TR on dirt rd along _____ S. R. No. _____

SUBDIVISION NAME Imperial Point LOT NO. 7 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area ½ Acre


Character & Porosity of Soil Sandy clay loam - Fair

Percolation Rate Not Taken

Topography 2% Slope

Depth to Water Table 5 ft 8"

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 225 Linear Ft. 250
Depth of Stone in Lines 24

Water Supply: Individual (✓)
Public ( )

Installed by Clyde Hall

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold