4635-57-2536

**IREDELL COUNTY HEALTH DEPARTMENT** **COPY**

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tom Lorenzin DATE Jan 10, '78 PERMIT NO. 9

PHONE: Business _____ Home _____

LOCATION 1100 T.L. on 1112 past water tank TR at end T.L. ¼ mi. on Rt. S. R. No. _____


SUBDIVISION NAME Bayview Estates LOT NO. 22 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | clay loam |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | F-G To |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | sunk. |
| | | | Rock or other impervious formations | none obs. |

Lot Area ½ Ac.



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Blake Hyde
Mark Co.

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Harold R. Johnson DATE Jan. 10, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold