4635-57-3378

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ryan Long DATE 10-12-22 PERMIT NO. 16

PHONE: Business _____ Home 237-9390

LOCATION 100 Plum Hill Dr Troutman NC Exit 45 on left

S. R. No. _____

SUBDIVISION NAME Tupelo Trail LOT NO. 1 SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes ( ) No (X)
Auto. Wash. Machine Yes ( ) No (X)
Site Suitable Yes (X) No ( )

Lot Area 1 Acre

Character & Porosity of Soil Clay Loam Loose
Percolation Rate 30 min/in
Topography Level
Depth to Water Table 20 ft
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 225 Linear Ft. 450
Depth of Stone in Lines 12 in
Water Supply: Individual (X)
Public ( )

Installed by Leonard Miller

IMPROVEMENTS PERMIT BY J. C. Miller

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Leonard DATE 10-21-22

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold