4635-57-4629

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ted Reavis DATE 2-5-86 PERMIT NO. 55

PHONE: Business _____ Home _____

LOCATION 1100 TL 1112 TR 1267 (Bay view Shore) 1st entrance
1/3 mile on left before Imperial Court Road S. R. No. _____


SUBDIVISION NAME Bayview Shores Estates LOT NO. 25 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2½
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 20,000 ft²

Character & Porosity of Soil Clay
Percolation Rate 0.39 11ft²/day
Topography 2 6 4p
Depth to Water Table _____
Rock or other impervious formations None obs

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Hinkle

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Well not put down yet needs to be 50' away from tank & lines (MINIMUM)

CERTIFICATE OF COMPLETION BY Charles K. Barnett DATE 2-5-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____
CONSTRUCTION MUST COMPLY WITH ALL REGULATIONS.
Permit is VOID if any unauthorized changes are made
Improvements Permit.

The proposed / existing Deck Repair addition does not appear to impact the existing septic system.

**NOTE: _____

Judy Melville R.S.
Date: 7-16-12
ICHD-Environmental Health Division

Health Dept. Copy: White Inspector: Gold