4635-57-5796

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Agostino Dimillo DATE 8-26-96 PERMIT NO. 239

PHONE Business _____ Home _____

LOCATION 1100 TL on 1112 at cnt TR 1/4 mi. on right


S. R. No. _____

SUBDIVISION NAME Bayview Estates LOT NO. 45 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam Porosity Fair
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	not taken
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	7-20% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'±
Lot Area ½ acre			Rock or other impervious formations	none



Plot of System

Size of Tank 1000 Gal.

Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin

Washing machine 250 sq ft

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Nitrification Ditch was dropped due to repositioning of house.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 8-26-96

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold