IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mady Const. Co. DATE 7-1-77 PERMIT NO. 174

PHONE: Business 528-7740 Home

LOCATION 1100 Th on 1112 near end

S. R. No.

SUBDIVISION NAME Imperial Point LOT NO. 21 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area Existing

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate Soil borings
Topography > 20% Slope
Depth to Water Table 6 to 8' to lake level
Rock or other impervious formations none



Plot of System

Size of Tank 1250' Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 700 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Ronnie Oaks

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-1-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold