4635-58-1381

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

COPY

OWNER OR CONTRACTOR Melvin Dixon DATE 1-27-84 PERMIT NO. 23

PHONE: Business _____ Home _____


LOCATION 1109 TR 1112 TR 1267 Ahead bear left on left S. R. No. _____

SUBDIVISION NAME Briarwood Estates LOT NO. 31 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	0-5 min 1" in 10 min
Auto. Wash. Machine	Yes (X)	No ( )	Topography	10-15%
Site Suitable	Yes (X)	No ( )	Depth to Water Table	4'
Lot Area 20,000 Ft²			Rock or other impervious formations	None observed



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 5
Sq. Ft. 1080 Linear Ft. 360
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 1-27-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold