DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Alan Campi
ADDRESS: ___
APPLICANT: ___
APPLICATION DATE: ___
PROPOSED FACILITY: ___
PROPOSED DESIGN FLOW (.1949): ___
DATE EVALUATED: 10/20/09
LOCATION OF SITE: 108 Bayview Lot 38 Bayview
PROPERTY SIZE: ___
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___
PROPERTY RECORDED: ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
SE = Slightly Expansive

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTA
1	L 4%10	0-4	Brw GR SCL/CL	FR SE SS, SP	—				PS .25
		4-24	Rd C m SBK	SS, SE, SP	—				
		24-36	Rd Cm-w SBK	SS-S, SP, SE	—				
		36-48	Rd/Brw C/CL m-w SBK	SS, SP, SE	—	48"	N/A	N/A	
2	2%10	0-6	Brw GR SCL	FR SE SS SP	—				PS .3
		6-20	Rd C m SBK	SS SP SE, FR	—				
		20-48	Rd CL w SBK	w SBK, SS, SP SE	—	48"	N/A	N/A	
3	2%10	0-12	Brw GR LL/SCL	FR, SE SS SP	—				PS .3
		12-30	Rd C/CL m-w SBK	SS, SE SP	—				
		30-48	Rd CL m-w SBK	SS, SP, SE	—	48"	N/A	N/A	
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	System installed 1971	Lot deeded prior to 1971
System Type(s)	Grav Conv Red	Grav 25% Red
Site LTAR	.25	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Maria Dotson
OTHER(S) PRESENT: ___