4635-58-5393

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack E Whitt DATE 1-4-78 PERMIT NO. 4

PHONE: Business _____ Home 547-8786

LOCATION 400 ft on 112 to at End 2nd Rd TR 200' on Right S. R. No. _____

SUBDIVISION NAME Bayview Estates LOT NO. 48 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 138 X 143


Character & Porosity of Soil Clay loam

Percolation Rate 60 min/in

Topography 2% Slope

Depth to Water Table 10 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 1
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 18"

Water Supply: Individual (✓)
Public ( )

Installed by J.R. Rawls

IMPROVEMENTS PERMIT BY David Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 1-4-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold