4635-58-5393

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack E Whitt DATE 1-4-78 PERMIT NO. 4

PHONE: Business ______ Home 847-8786

LOCATION 1100 TL on 1112 TR at End 2nd Rd TR 200' on Right S. R. No. ______

SUBDIVISION NAME Bayview Estates LOT NO. 48 SECTION OR BLOCK NO. ______

House (✓) Mobile Home ( ) Business ( ) Other ______

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 139' x 143'


Character & Porosity of Soil Clay loam

Percolation Rate 60 min/in +

Topography < 2% Slope

Depth to Water Table 10 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 12"

Water Supply: Individual (✓) Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY David Henson

COMMENTS: ______

CERTIFICATE OF COMPLETION BY John Haynes DATE 1-4-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold