4635-58-[redacted]
6917

12230

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Everett Auten DATE Jan. 2, '91 PERMIT NO. 2C-8-A-32

PHONE: Business _____ Home _____

LOCATION 1100 TR 1112 (Stutts Rd.) TR 2nd Southwood on left


SUBDIVISION NAME Marina Village LOT NO. 32 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	ps clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	1 in 4 ½	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2%	
Site ~~Suitable~~ PS	Yes (✓)	No ( )	Depth to Water Table	4'+	
Lot Area 20000ft²+			Rock or other impervious formations	none obs.	

____ Basement with Plumbing ____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Owner

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY KRS

COMMENTS: Neighbor's well
System installed prior to construction of house.

CERTIFICATE OF COMPLETION BY David R. Hinson, EHS DATE Jan. 2, '90

SEWAGE SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
This is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold