4635-58-9283

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. C. Lindsay DATE 10-1-85 PERMIT NO. 426

PHONE: Business _____ Home _____

LOCATION 400 ft 1/2 Co to END SR 1267 ON CORNER of 1268 And 1267

SUBDIVISION NAME Imperial Point LOT NO. 46 SECTION OR BLOCK NO. _____ S. R. No. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No (X)

Auto. Dishwasher Yes (X) No ( )

Auto. Wash. Machine Yes (X) No ( )

Site Suitable Yes (X) No ( )

Lot Area 18,768 Sq Ft Lot Recorded Prior to 1973

Character & Porosity of Soil Clay loam - silty pan


Percolation Rate 0.5 gpm/sq ft

Topography Level

Depth to Water Table 4 ft

Rock or other impervious formations None obs.

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 24

Water Supply: Individual (X)

Public ( )

Installed by Leon Burton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Shoreline Drive (1267)

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 10-1-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold