4635590402

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. Builders DATE 5-2-79 PERMIT NO. 118

PHONE: Business _____ Home _____

LOCATION 1100 T.L. on 1112

S. R. No. _____


SUBDIVISION NAME Marina Village LOT NO. 2 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	5
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk.
			Rock or other impervious formations	none obs.

Lot Area ½ Ac. +



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Arnie Duncan for Hope Bros.

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Harold R. Hinson DATE 5-2-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold