4635-59-2331

IREDELL COUNTY HEALTH DEPARTMENT

12827 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sidney H. Blankenship DATE 9/12/91 PERMIT NO. NOT WRITTEN ON PD FORM

PHONE: Business _____ Home 528-4224

LOCATION Stutts Rd, TR on Southwood, Lee (L) to Groundhog Freedom (L), TL last lot on (L) at end of road S. R. No. _____

SUBDIVISION NAME Marina Village LOT NO. 40 SECTION OR BLOCK NO. _____

House (Y) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (Y)	
Auto. Dishwasher	Yes (Y)	No ( )	
Auto. Wash. Machine	Yes (Y)	No ( )	
Site Suitable	Yes (Y)	No ( )	

Character & Porosity of Soil P - sic
Percolation Rate 3
Topography 2%
Depth to Water Table 4' +
Rock or other impervious formations none found

Lot Area 20,000 FT²

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System ROAD.

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5 @ 80' x 3'
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12
Water Supply: Individual (Y)
Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 9/19/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold