NT OF ENVIRONMENT AND NATURAL RESOURCES
F ENVIRONMENTAL HEALTH
STEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Peter Gjuraj
ADDRESS: _____
APPLICATION DATE _____
DATE EVALUATED: 7-26-07
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 480 gpd
LOCATION OF SITE: Marina Village #34
PROPERTY SIZE: _____
PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-10	gr sl/ Br						PS .3
		10-30	sbk cl/scl	fr ss sp	vf-mn R/Br				
		30-45	sbk c/cl	fr ss sp SE	Red		Mieaceous		
		45-48	sbk cl	fr ss sp			c-sap		
2		0-8	gr sl	vfr ss sp	Br				PS .3
		8-28	sbk cl/scl	fr ss sp	Br				
		28-44	sbk c	fr ss sp	Red				
		44-48	sbk cl	fr ss sp			c-sap		
3		0-10	gr sl						PS .3
		10-24	sbk cl/scl	fr ss sp					
		24-31	mod sbk c/cl	few fi - v. any fr - ss sp SE					
		31-45	sbk cl/scl	fr ss sp					
		45-48	cl + sap	fr ss sp			c-sap m-sap		
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Yes	Partial
System Type(s)	25% pm	LPP Panel
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: J. Melville
OTHER(S) PRESENT: Peter Gjuraj
COMMENTS: _____