DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Alan Brown APPLICANT: Same
ADDRESS: 297 Commodore Lp. APPLICATION DATE: _____ DATE EVALUATED: 5/5/04
PROPOSED FACILITY: 3BD/Home PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~, 33 Ac
LOCATION OF SITE: Lot 105 Com. Pen. PROPERTY RECORDED: < 1985
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☒ Other Comm.
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4-6% L Front	0-7	fSD GR-S cl	FR SS-SP					.2
		8-26 TM ~C		FR S-P					
		27-33	GR MSDK cl SAP	FR SS-SP					.3
		34-44	GR - l SAP	VFR SS-NP					
2	4% L Mid	0-6	fSD GR cl BR	FR SS-SP					
		7-21	MN MABK & (R)	FI S-SP					
		22-48	GR MSBR INCL cl SAP	VFR SS-NP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____