# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR K. C. Broadaway DATE 2-3-75 PERMIT NO. 150

PHONE: Business 528-4591 Home

LOCATION 1303 R Then 1407 R on 1460 at end

S. R. No.


SUBDIVISION NAME Lake Norman LOT NO. 158 SECTION OR BLOCK NO. 16

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | Sandy loam Porous to Good |
| Auto. Dishwasher | Yes ( ) | No (✓) | Percolation Rate | 16 Inches |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | 2 to 5% Slope |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | 8 to 10' |
| | | | Rock or other impervious formations | None |

Lot Area 5 acre




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 425 Linear Ft. 250
Depth of Stone in Lines 12

Water Supply: Individual (✓)
Public ( )

Installed by Sam Stuart

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY John Houston DATE 2-3-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold