IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR B. R. Egan DATE 10-20-96 PERMIT NO. _____

PHONE: Business _____ Home 528-1394

LOCATION 1100 Th on 1112

S. R. No. _____

SUBDIVISION NAME Commodore Pnt LOT NO. 102 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 12,500 Sq Ft

Character & Porosity of Soil Clay loam Porosity Fair to
Percolation Rate Soil Borings
Topography 22% slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Wayne Orbison

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Soil is partly rock fillet

CERTIFICATE OF COMPLETION BY _____ DATE 11-21

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold