4635-69-5673

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gerald R. Hinton DATE _____ PERMIT NO. 1910

PHONE: Business _____ Home 662-7306


LOCATION 1.1 mi. TL on 1112 TL on Cinnamon Lake Dr. 1500' on lot

SUBDIVISION NAME Cinnamon Lake Peninsula LOT NO. 161 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair line

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	Porosity Fair
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	70+ Fair	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 20% slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+	
Lot Area ½ acre			Rock or other impervious formations	none	



Plot of System

Road

Size of Tank Existing Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 390.0 Linear Ft. 156

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by E. J. Service

IMPROVEMENTS PERMIT BY John Hairston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 8-31-9

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold