IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ed Miller DATE 7-30-74 PERMIT NO. 204


PHONE: Business _____ Home _____

LOCATION 150 W - 1109 Turn Left 1100 Turn Rt Turn Left go 1½ mi First Rd past water Tank Turn Left 1st Drive Rt 600 ft house S. R. No. _____

SUBDIVISION NAME Commander Peninsula LOT NO. 99 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3	No. Bathrooms 2½	Character & Porosity of Soil	Red Clay + Mott'l Co
Garbage Disposal Unit	Yes ( ) No (✓)	Percolation Rate	60+
Auto. Dishwasher	Yes ( ) No (✓)	Topography	Slope to Left x-con
Auto. Wash. Machine	Yes ( ) No (✓)	Depth to Water Table	10'+
Site Suitable	Yes (✓) No ( )	Rock or other impervious formations	None
Lot Area 150 x 175 +/- Prox			



Plot of System

Size of Tank 1100 Gals.

Nitrification Field:

No. of Lines 6 (3 per system)

Sq. Ft. 1008 Linear Ft. 336

Depth of Stone in Lines 10

Water Supply: Individual (✓)

Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY C. L. Causey

COMMENTS: House not on lot 90 ms to use for Camper until House is built

CERTIFICATE OF COMPLETION BY _____ DATE 7-30-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold