4635698730

IREDELL COUNTY HE[illegible]H DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Nick C. Wagg DATE 6-20-84 PERMIT NO. 198

PHONE: Business _____ Home _____

LOCATION 1112 To 1212 ¾ mile on left

S. R. No. _____

SUBDIVISION NAME Commodore Peninsula LOT NO. 165 SECTION OR BLOCK NO. _____


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes (X) No ( )
Auto. Wash. Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )

Lot Area 10,582 ft² Lot Recorded Prior to 1973

Character & Porosity of Soil Clay
Percolation Rate 0.5 gal/ft²/day 6-20-84
Topography _____
Depth to Water Table _____
Rock or other impervious formations NONE obs



Plot of System

Size of Tank 1000 Gals.
Nitrification Field: 5
No. of Lines
Sq. Ft. 1080 Linear Ft. 360
Depth of Stone in Lines 12
Water Supply: Individual ( )
Public (X)

Installed by J. J. Erwin Co

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer

EXISTING SYSTEM CHECKED BY: _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCA

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is sup Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner