10307

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR H+P Construction DATE Mar 14, 1990 PERMIT NO. ZB-1-C-31

PHONE: Business _____ Home _____

LOCATION Langtree Rd. TR 2nd Lakeview Shore Drive 3rd lot on R S. R. No. _____

SUBDIVISION NAME Lakeview Shores LOT NO. 31 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	.35 gpd/ft²
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-8%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none obs

Lot Area _____ 2417 +or-

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 225
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by George Moser

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: D-Box with Speed Levelers 4:2 Reducers

CERTIFICATE OF COMPLETION BY Sam Ingram E.H.S. DATE Mar 14, 1990

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold