IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joe Blanton DATE 9-22-77 PERMIT NO. _____

PHONE: Business _____ Home 664-2961

LOCATION 115 South TR on 1102

S. R. No. _____

SUBDIVISION NAME Lakeview Shores LOT NO. 19 SECTION OR BLOCK NO. D


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay loam
Percolation Rate 60 min/inch
Topography 2220 Slope
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area ½ acre



Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 660 Linear Ft. 220
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Orbison

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 9-22-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold