IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO 15702 DATE Oct 22, '93 TAX MAP NO 2GGA74 Watershed: ☑ Yes ☐ No

OWNER OR CONTRACTOR Gary & Rhonda Baumgarner PHONE: Business ~~Home~~ 4635-79-2394 LAKE NORMAN

ADDRESS

LOCATION 1100 TR 1112 TR 2nd 1212 TR Sunfield Dr. on left

SUBDIVISION Commodore Pen. BLOCK / SECTION LOT 74 LOT AREA 70 x 143' SITE CLASS 5 per 1996 DESIGN FLOW 360 gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1012 Tay. Date 8-393

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet Linear Feet 200

No Lines 4 Trench Width 24" Max Trench Bottom Depth ~30 Gravel Depth N/A

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: Gravity PPBPS

Repair System Description: Grav/LP PPBPS

Maintenance Agreement Required: ☐ Yes ☐ No

☑ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 2½

☐ Business No. Employees

☐ Other

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing


Water Supply: ☐ Individual ☑ Community ☐ Public

Comments:

Comments:

INITIAL SITE SKETCH

~~AS~~ BUILT SKETCH



I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed:

Improvement Permit by: date

Existing System Inspection by: date

Installed by: Tommy Frye

Certificate of Completion by: date

Operation Permit by: date 10/22/93

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD