14476

IREDELL COUNTY HEALTH DEPARTMENT 4635-79-2815

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Spear Const. DATE Aug. 27 '92 PERMIT NO. 26-6A169

PHONE: Business _____ Home _____

LOCATION 1100 TL 112 TL 2nd L 212 (Commodore Dr.) TL Rhinecrest ½ mile on right S.R. No. _____

SUBDIVISION NAME Commodore Peninsula LOT NO. 189 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 70'X143' EXISTING

Soil Characteristics B clay


Application Rate .3 gal/SF/day

Topography 2-4%

Depth to Water Table 24"

Rock or other impervious formations NONE OBS

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. _____ Linear Ft. 200' of

Depth of Stone in Lines 16" OBS

Water Supply: Individual ☐

Public ☑ CW

Installed by Rowan Septic Tank

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY _____

COMMENTS _____

CERTIFICATE OF COMPLETION BY D.R. Hinson, RS DATE 8/27/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold