DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 266A75
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Grant Williams OWNER: / AGENT: PHONE:
ADDRESS: Rt 9 Box 853-A APPLICATION DATE: 6/1/93 DATE EVALUATED: 6/7/93
Mooresville, NC PROPOSED FACILITY: 3 bedroom single family dwelling
Lot 75, Commodore PROPERTY SIZE: 70' x 143'
LOCATION OF SITE: SR 1100 TR 1112 / TR 2nd R 2.12 TR Seaside DR. on left near end
WATER SUPPLY: On-Site Well ___ Comm. Well / Public ___ Other ___ EVAL METHOD: Auger Boring / Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	55	0-5	sbk gr cl.	fi dy 1:1	NONE	NONE	P.S.	—	.35
		5-12	sbk c	sf 1:1					.3
		12-48	w sbk stc l	fr 1:1					.25
2									
3									
4									
5									

AVAILABLE SPACE (.1945) U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [signature] OTHER(S) PRESENT: Grant Williams
COMMENTS: site can be reclassified PS under rule 1956 / modified systems PPBFS