IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 209859

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4635-79-4173

APPLICANT: JACOB DEMRIN APPLICANT ADDRESS: 146 SURFSIDE LN. MOORESVILLE

SITE ADDRESS: 146 SURFSIDE PHONE: ALT. PHONE:

SITE DIRECTIONS: STUTTS, TL 2ND COMMODORE, TR SURFSIDE, ON R

SUBDIVISION: COMMODORE PENNINSULA SECTION: LOT # 85 LOT AREA: DESIGN FLOW: 360 L.T.A.R.: .3

Septic Tank 1000 (gal) STB 794 Date 8-12-15
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 4 @ 50' Linear Ft: 200'
Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type: I II ☒ III IV V VI
System Description: PANEL BLOCK
Repair System Description: ≤ 1983 PARTIAL
Maintenance Agreement Required: ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 3
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions: WATER LINE IN SYSTEM AREA MUST BE RE ROUTED MIN 10' FROM SEPTIC

INITIAL SITE SKETCH

SEE PLAN FROM MICHAEL ATHANAS & ASSOCIATES

AS BUILT SKETCH

Instelled as drawn

- No water line was found during install

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**


☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 8-4-15 Installed by: Abernathy

IMPROVEMENT PERMIT by: APPROVED APR 28 2015 Date: OPERATION PERMIT by: Date: 9-21-15

AUTHORIZATION TO CONSTRUCT by: APPROVED MAY 13 2015 Date: Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK



INITY MAP NO SCALE

APPROVED APR 2 8 2015

LAKE NORMAN

760 CONTOUR LINE

N75°28'00"W 34.81

S64°24'00"W 40.49

W1

P2

O-3

SETBACK 84

5'

5'

6.7'

5T

5.5'

Deck

LOT 85

15' SIDE

House

160.75 S01°15'00"W

N01°15'00"E 171.04

73'

LOT 84

LOT 86

N

DRIVE

15' SIDE

35' FRONT

Partial Repair Area

S88°45'00"E 70.00

Scale 1"=30'

SURFSIDE DR. (60' PUBLIC R\W