4025176125 7025112180

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Frances Horton DATE 2-6-74 PERMIT NO. 11

PHONE: Business _____ Home _____

LOCATION Commodore Penn. off Road 1112

S. R. No. 1112

SUBDIVISION NAME Commodore Penn LOT NO. 5 183 & 184 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	( )	No	(✓)	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area ½ acre


Character & Porosity of Soil Cecil sandy loam

Percolation Rate fast taken

Topography < 20% Slope

Depth to Water Table 10'

Rock or other impervious formations 5 to 15' to bedrock



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 640 Linear Ft. 256
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by James Stewart
Charlotte, N.C.

IMPROVEMENTS PERMIT BY E. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. C. Moore DATE 2-6-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold