4035796298

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sidney Cook DATE 10-20-75 PERMIT NO. 06

PHONE: Business _____ Home 1-704-545-5034

LOCATION 1100 TL on 1112 TL on Commodore Drive (1st on L)

S. R. No. _____


SUBDIVISION NAME Commodore Peninsula LOT NO. 80 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Existing
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	System

Lot Area ¼ acre Existing lot



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Sam Oswalt
1974

IMPROVEMENTS PERMIT BY _____

COMMENTS: system is adequate for proposed House

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 10-20-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Mooty DATE 4-30-74 PERMIT NO. 107

PHONE: Business _____ Home 597-8263

LOCATION 1100 TL on 1112 Turn into Commodore Penn

S. R. No. _____

SUBDIVISION NAME Commodore Peninsula LOT NO. 80 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No (✓)	
Site Suitable	Yes (✓)	No ( )	

Lot Area 12,000 Sq feet


Character & Porosity of Soil Sandy clay loam Porosity good

Percolation Rate 25 min/inch

Topography 3% slope

Depth to Water Table 10'+

Rock or other impervious formations None (Sand Stone in bottom of hill)



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Sam Oswalt

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 4-30-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold