IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Sidney Cook DATE 10-20-75 PERMIT NO. 06

PHONE: Business _____ Home 1-704-545-5034

LOCATION 1100 ft. to 1st on, 1112 T to L on commodore Drive

S. R. No. _____

SUBDIVISION NAME Commodore Peninsula LOT NO. 80 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area ¼ acre Existing lot

Character & Porosity of Soil _____
Percolation Rate _____
Topography Existing
Depth to Water Table _____
Rock or other impervious formations System



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public ✓

Installed by Sam Oswalt
1974

IMPROVEMENTS PERMIT BY _____

COMMENTS: System is adequate for proposed House

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 10-20-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold