4025170125 4025110180

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Frances Horton DATE 2-6-74 PERMIT NO. 11

PHONE: Business _____ Home _____

LOCATION Commodore Penn. off Road 1112

S. R. No. 1112


SUBDIVISION NAME Commodore Penn LOT NO. 183 & 184 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Sandy loam	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	Fast to Med	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-8% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'	
			Rock or other impervious formations	5 to 15' to bedrock	

Lot Area ½ acre



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 252
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by James Stewart
Charlotte, N.C.

IMPROVEMENTS PERMIT BY E. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. C. Moore DATE 2-6-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold