4635797965

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Billy Mayhew DATE 6-4-15 PERMIT NO.

PHONE: Business Home 663-3814

LOCATION 100 ft on Hwy 70 E of water Tank
½ mi on right S. R. No.

SUBDIVISION NAME Emerald Peninsula LOT NO. 150 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)	Percolation Rate NOT Tested
Auto. Dishwasher	Yes	( )	No	(✓)	Topography 2% Slope
Auto. Wash. Machine	Yes	(✓)	No	( )	Depth to Water Table 10'
Site Suitable	Yes	(✓)	No	( )	Rock or other impervious formations None

Character & Porosity of Soil Clay loam Loamy Fill

Lot Area 1.2 Acre
Existing



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 24"

Water Supply: Individual (✓)
Public ( )

Installed by F.J. Erwin

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY Robin Hendrix DATE 6-4-15

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold