IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jim Martin DATE 6-23-76 PERMIT NO. 164

PHONE: Business 704-932-7476 Home

LOCATION 1100 ft on 1112

S. R. No.

SUBDIVISION NAME Commodore Lane LOT NO. 45 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area Existing Lane

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate Not Taken
Topography Rolling Slope
Depth to Water Table 5 ft. to 8'
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 225 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Kannapolis Sewer Co.

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY John Houston DATE 6-27-

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold