IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Glenn Belvin DATE 5-21-79 PERMIT NO. 159

PHONE: Business _____ Home _____

LOCATION 1155 TR on 1102

S. R. No. _____

SUBDIVISION NAME Lakeview Shores LOT NO. 15 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ½ Ac.

Character & Porosity of Soil Clay loam
Percolation Rate 60 mpi +
Topography Gently
Depth to Water Table 6'-8'
Rock or other impervious formations none obs.



Plot of System

n 500 gal. pump tank

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Sam Osteen

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Layout changed to get footage and stay out of Lake water.

CERTIFICATE OF COMPLETION BY Marvel R. Henson DATE 5-21-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold