IREDELL COUNTY HEALTH DEPARTMENT 4635803172

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Keith Carroll DATE 5-7-81 PERMIT NO. 131

PHONE: Business _____ Home _____

LOCATION 1102 just past Main entrance to Lakeview Shores ~¼ mile on R S. R. No. 1102

SUBDIVISION NAME Lakeview Shores LOT NO. 6 SECTION OR BLOCK NO. A

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(X)
Auto. Dishwasher	Yes	(X)	No	( )
Auto. Wash. Machine	Yes	(X)	No	( )
Site Suitable	Yes	(X)	No	( )

Lot Area 20,000 ft²

Character & Porosity of Soil Clay loam
Percolation Rate 80 mpi
Topography 2-4%
Depth to Water Table unknown
Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (X)
Public ( )

Installed by F. J. Ervin Co

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ORH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 5-7-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold