4635803398

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Stuart Howard DATE July 14, '78 PERMIT NO. 163

PHONE: Business _____ Home _____

LOCATION 115 Turn on 1102 (to - 2mi T.L. then Turn on 1st Rt 1/4 mi on Left S. R. No. _____


SUBDIVISION NAME Edwin Howard LOT NO. 26 SECTION OR BLOCK NO. 4

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay Loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	2
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-7%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4 ft.
			Rock or other impervious formations	None Known

Lot Area 1 Acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10" ±

Water Supply: Individual (✓)
Public ( )

Installed by Hicks Septic Tank Co.

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Howard K. Stevens DATE July 14, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold