SHEET ___ OF ___

DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Vernon Grier OWNER ___ AGENT: ___ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED ___
PROPOSED FACILITY: _____
PROPERTY SIZE: _____

LOCATION OF SITE: Lot 24 Lakeview Shores
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1		0 to 4	L	GR				.1942 Wetness Cond. - N/A
	linear	4 to 28	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
		28 to 48	C	weak SBK	1:1			.1944 Restrictive Hori. - N/A
	H90							.1948 Profile Class. - PS
								Profile LTAR - .3
2		0 to 4	L	GR				.1942 Wetness Cond. - N/A
	linear	4 to 32	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	H90	32 to 48	C	weak SBK	1:1			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) yes OTHER FACTORS (.1946) _____ SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE Gravity/Panel LONG-TERM ACCEPTANCE RATE(S) .3

EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Sonja Smith

COMMENTS: _____