IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dave Supply DATE 8-6-76 PERMIT NO. 206

PHONE: Business _____ Home _____

LOCATION 115 TR 20 NO 2

S. R. No. _____

SUBDIVISION NAME Lake View Shores LOT NO. 18 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area ½ acre

Character & Porosity of Soil Clay loam Fair
Percolation Rate Not Taken
Topography 2 to 5% Slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Brisco

IMPROVEMENTS PERMIT BY John Hewitt

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Hewitt DATE 8-6-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold