03752

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald Whitley DATE July 22, '88 PERMIT NO.

PHONE: Business Home

LOCATION 115 S. TR 1102 (Longtree) TR 2nd Lakeshore Drive on left in curve S. R. No.

SUBDIVISION NAME Lakeview Shores LOT NO. 10 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 3½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ PS Yes (✓) No ( )

Lot Area 20000 sq ft

Character & Porosity of Soil clay

Percolation Rate 2.3

Topography rolling


Depth to Water Table 3'+

Rock or other impervious formations none obs.

1000 pt. OPH

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement

(May Need Sump pump for basement)



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2 (ns)

Sq. Ft. Linear Ft. 200'

Depth of Stone in Lines 16" Trench

Water Supply: Individual (✓)

Public ( )

4" SCH 40 PVC with 4"x2" reducer

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Donald H Whitley

IMPROVEMENTS PERMIT BY DR Henson RS.

COMMENTS: Panel drainfield must be installed so bottom of drainfield ditch is 1 foot above Lake 760. Install drainfield at a depth of 28" to bottom of ditch, 6" natural cover, and mound over with excess dirt. If basement plumbing will not accomodate this depth, then pumping will be required.

CERTIFICATE OF COMPLETION BY DATE

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

6-26-90 LP panel drainfield now required because of basement (drainfield to be in front (roadside) Robert