4635852760

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James O Hensley DATE 5-15-84 PERMIT NO. 135

PHONE: Business _____ Home _____

LOCATION 21 South x I 77 TL 1206 TR 1108 T L 11883 (EL Comino Road Real) at end on culde sac on left S. R. No. _____


SUBDIVISION NAME Lakeview Park LOT NO. 14 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	clay
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	0.5
Auto. Wash. Machine	Yes (X)	No ( )	Topography	
Site Suitable	Yes (X)	No ( )	Depth to Water Table	
			Rock or other impervious formations	NONE

Lot Area 25,283+/-



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1080 Linear Ft. 360
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore (Charles Y. Barnett) DATE 5-15-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold