4635856956

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hubert Cannon DATE 5-10-18 PERMIT NO. 30

PHONE: Business _____ Home 919-629-2425

LOCATION _____

_____ S. R. No. _____


SUBDIVISION NAME Lakeview Park LOT NO. 18 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No ( ) | Character & Porosity of Soil | Clay Loam |
| Auto. Dishwasher | Yes ( ) | No ( ) | Percolation Rate | 120 min/in |
| Auto. Wash. Machine | Yes ( ) | No ( ) | Topography | Rolling |
| Site Suitable | Yes ( ) | No ( ) | Depth to Water Table | 48" |
| | | | Rock or other impervious formations | None |

Lot Area ½ acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Lower System 6 x 25' = 150 sq ft

Installed by E.J. Sims

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Hunsucker DATE 5-24-18

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold