IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Herbert Cameron DATE 5-12-78 PERMIT NO. 80

PHONE: Business _____ Home 919-679-2425

LOCATION _____

_____ S. R. No. _____


SUBDIVISION NAME Lakeview Park LOT NO. 18 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	120 min/in
Auto. Wash. Machine	Yes ( )	No ( )	Topography	2% Slope
Site Suitable	Yes ( )	No ( )	Depth to Water Table	6' to 8'
			Rock or other impervious formations	None

Lot Area ½ acre



Plot of System

Size of Tank 2 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Lower System 6 x 75' 450 Sq Ft 150 Lin Ft

Installed by F. J. Ewing

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 5-11-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold