Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 1 OF 1
PIN #: 4635-91-1539
Lot #: 12
Permit #: 173559
AppID:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: **TERESA STROUD**
Applicant: **CHERYL&NICK HARVEY**
Address: **000 LAKESHORE DR.**
Date Evaluated: **8/1/2012**
Proposed Facility: **SFR** Design Flow (.1949) **480**
Property Size: **.48 AC**
Location of Site: **LAKEVIEW SHORES LOT 12**
Property Recorded: **YES**
Water Supply: [ ] Public [X] Individual [X] Well [ ] Spring [ ] Other
Evaluation Method: [X] Auger Boring [ ] Pit [ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		b PROFILE FACTORS				
			1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horiz	Profile Class & LTAR
AB 1	LINEAR 4%	0-25	SCL,W,SBK	SS	NA	48"	NA	48"+	.35
		25-45	SC,M,SBK	SS					
		45-48	SCL,M,SBK	SS					
AB 2	LINEAR 4%	0-48	SCL,W/M,SBK	SS	NA	48"	NA	48"+	.35
AB 3	LINEAR 5%	0-36	SCL,W,SBK	SS	NA	48"	MANY SAP @ 36"	48"+	.35
		36-48	SCL,W,SBK	SS					
AB 4	LINEAR 5%	0-27	SCL,W,SBK	SS	NA	48"	MANY SAP @ 27"	48"+	.35
		27-48	CL,W,SBK	SS					

Description	Initial System	Repair System
Available Space (.1945)	PS	PS
System Type(s)	LP-PANEL	LP-PANEL
Site LTAR	.35	.35

Other Factors (.1946):
Soil Evaluation By: **BEN ALDRIDGE**
Others Present: **NONE**
Site Classification (.1948): **PS**
Site Evaluation By: **BEN ALDRIDGE**
Others Present: **NONE**