IREDELL COUNTY HEALTH DEPARTMENT

1837

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C) 4635-91-3595

OWNER OR CONTRACTOR James F. Rittenmeyer DATE Nov. 5, '90 PERMIT NO. 2B-1-A-17

PHONE: Business _____ Home _____

LOCATION 11.5 S. TR 1102 (Langtree) TR 2nd Lakeshore DR. ½ mile on left

S. R. No. _____

SUBDIVISION NAME Lakeview Shores LOT NO. 17 SECTION OR BLOCK NO. D

LAKE

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )

Auto Dishwasher Yes (✓) No ( )

Auto Wash. Machine Yes (✓) No ( )

Suitable PS Yes (✓) No ( )

Lot Area .18 Ac.

Character & Porosity of Soil low range ps. clay


Percolation Rate 2

Topography 4-6%

Depth to Water Table 4'+

Rock or other impervious formations none obs.

Basement with Plumbing _____ Basement without Plumbing _____ No Basement



1500 p.t.

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. 300'
Depth of Stone in Lines 16"+8"

Water Supply: Individual (✓) private pressure dosed
Public ( )

Installed by Ken Painter & Iron Horse Grading

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Access Road

IMPROVEMENTS PERMIT BY _____

COMMENTS: Repair Area Lakeshore DR.

Alarm not permanently mounted yet, but tested & working

Operation permit

CERTIFICATE OF COMPLETION BY _____ DATE 11-5-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold