IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 148044 Cassidy PIN# 4635979197 139 Camino Real DATE 3-26-08

OWNER OR APPLICANT Spivey Construction Company Inc / PHONE: Business 704-663-4489 Home

ADDRESS PO Box 4268 Mooresville NC 28117 / Bruce Cassidy

LOCATION Hwy 21 S cross I-77 TL Alcove TR Templeton TL Camino Real 1 mile on right

SUBDIVISION BLOCK / SECTION LOT TR2 LOT AREA 2.284 SITE CLASS. PS DESIGN FLOW 960gpd L.T.A.R. .3gpd/ft2

* Septic Tank: 2000 Gallons; STB 633 Date 3/11/08

* Pump Tank: 2500 Gallons; PT 96 Date 11/3/08

Pump Make: Zoeller Model N-137 Serial No.

Nitrification Field: No Fields 1 Square Feet 1112 Linear Feet 556

No Lines 8 Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 8 No. Persons 16 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

* Tanks traffic rated if greater than 36" deep

- Supply line min. 25' from well and must be ductile iron or water main std. if between 25' & 50'

Comments:/Conditions:

* Properly abandon existing well within house site before OP

INITIAL SITE SKETCH

- Supply line 36" below driveways, sidewalks and 12" separation from storm drains

See plan from Rollins Soil & Environmental Services including information for installer

Shared well between House & Kennel

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 3/31/08

Improvement Permit by: [signature] date 3-26-08

Authorization to Construct by: [signature] date 4-10-08

Installed by: G+M Const.

Operation Permit by: [signature] RS date 5/13/2010

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK