IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 18298 DATE April 13, 195 TAX MAP NO. 2G23A37 4636 003982 Watershed: ☑ Yes ☐ No WSIII

OWNER OR CONTRACTOR Crescent Resources Inc PHONE: Business _____ Home _____

ADDRESS PO Box 1003, Charlotte

LOCATION 1160 Tl Isle of Pines Rd TR Cove Oak Rd TL Wynnewpt TR Wynnward TL North Shore on Right

SUBDIVISION North Shore BLOCK / SECTION 1, 2 LOT 37 LOT AREA ± Ac SITE CLASS. PS DESIGN FLOW 660gpd L.T.A.R. .03

Septic Tank: 2000 Gallons; STB _____ Date _____

Pump Tank: 3000 Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 2 Square Feet 2200 Linear Feet 734

No Lines 8 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☑ New System ☐ Repair System Type: I, II, (III) IV, V, VI

System Description: pump to pon / conv field

Repair System Description: same

Maintenance Agreement Required: ☐ Yes ☑ No

☐ House/Mod. Home No. Bedrooms _____

☐ Mobile Home No. Bathrooms _____

☐ Business No. Employees _____

☑ Other Pool Amenity

☑ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply:
☐ Individual
☑ Community
☐ Public

Comments: Engineer to provide "As built" plan and written certification that final installation meets specified requirements.

Comments:

INITIAL SITE SKETCH

SEE ENGINEERED PLAN

AS BUILT SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed: _____

Improvement Permit by: _____, RS date 4/13/95

Existing System Inspection by: _____ date _____

Installed by: Ironhorse Grading

Certificate of Completion by: _____ date _____

Operation Permit by: _____ date 8-2-95

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD