DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RT Homes OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 12/2/94
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Lot 20 North Shore
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-6	gr-scL	1:1 (fr)					.3
		6-17	SAb-c	1:1 Mod fi					
		17-27	SAb-cL	1:1 fi					
		27-46	vwkSAb-cL	1:1 fi-fr					
			ww SAP Transmp	1:1					
2		0-10	gr-scL	1:1 fr					.3
		10-25	SAb-sc	1:1 Stky, Mpla					
		25-30	SAb-cL	1:1 fi					
		30-46	vwkSAb cL	1:1 fi-fr					
			Common mica flakes						
3									
4									
5									

AVAILABLE SPACE (.1945) ___ SITE CLASSIFICATION (.1948): ___ SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: DPH OTHER(S) PRESENT: Jim Warren
COMMENTS: Proposed site graded upper terrace / House site staked