DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RT Homes OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: Lot 22, North Shore phase 2 — Wynward Lane
WATER SUPPLY: On-Site Well ____ Comm. Well ✓ Public ____ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-11	SAB / CL	1:1 / fr Brn		2	PS		.4
		11-22	SAB / CL	1:1 / fi-fr Red Brn					.35
		22-45+	SAB / C	1:1 / fi-vfi Red					.3
2		0-14	SAB / CL	1:1 / fr			PS		.4
		14-26	SAB / CL	1:1 / fr-fi					.35
		26-39	SAB / C	1:1 / fi-vfi					.3
		39"	Hit rock at this level						
3									
4									
5									

AVAILABLE SPACE (.1948): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [signature] OTHER(S) PRESENT: Paul Swearinger
COMMENTS: ____