3100

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 138045 BF

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636013742

APPLICANT: Benitez Homes Inc APPLICANT ADDRESS: 184 N. Main St Waynesville, NC 28786

SITE ADDRESS: 257 Cove Creek Loop M'ville, NC PHONE: 828.246-9086 ALT. PHONE:

SITE DIRECTIONS: Brawley School Rd TL Isle of Pines TR Cove Creek on Rt. (past Community Pool)

SUBDIVISION: Chesapeake Pointe SECTION: LOT # 43 LOT AREA: 1.07Ac +.315AC DESIGN FLOW: 480gpd L.T.A.R.: .25

Septic Tank	1000 (gal)	STB	194	Date	5-23-14	☒ New System	☐ Repair	☐ Expansion	System Type: I II III IV V VI	☒ Residence	No. Bedrooms 4
Pump Tank	1000 (gal)	PT	27	Date	5-12-14	System Description:	Pump-PM-25% Reduction			☐ Business	No. Persons 8
Pump Make	Liberty	Model	283	Serial #		Repair System Description:	LPPPBPS			☐ Other	No. Employees
# Nitrification Fields	1	# Lines	6	Linear Ft:	480	Maintenance Agreement Required:	☐ YES	☒ NO		☐ Slab	☒ Crawl Space
Trench Width	36"	Max. Trench Bottom Depth	36"	Gravel Depth	N/A		☐ GRAVITY	☒ PRESSURE		☐ Basement w/plumbing	☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions: Note: Hug Property line with driveway

7/9/14 Checked tanks & lines MD

INITIAL SITE SKETCH

See Approved plan by Michael Athanasa Assoc (dated 2-21-14) attached

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 4-28-14 Installed by: Richard Abernathy

IMPROVEMENT PERMIT by: Maina H. Dotson RS Date: 3/11/14 OPERATION PERMIT by: Date: 7/14/14

AUTHORIZATION TO CONSTRUCT by: Maina H. Dotson RS Date: 3/11/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK