DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RI Homes OWNER: ___ AGENT: ___ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 11-8-95
PROPOSED FACILITY: 3 bdrm SFR - trench system
PROPERTY SIZE: ____
LOCATION OF SITE: Lot 44 NSE
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LSS 8-10%	0-7	gr-brn SL	1:1 fr					.25-.3
		7-18	gr.wksab brn cl	1:1 fr					
		18-34	SAB- RC	1:1 fi sbk					
		34-48	SAB R brn CL	1:1 fr, ss sp					
			some rock gravel						
2		0-14	gr-brn scl	fr					.25-.3
		14-34	m.wksab brn CL	fr fi ss sp	34"+				
		34-48	m.wksab light brn CL	fr fi ss sp					
3		0-9	gr-wksab brn scl	fr ss sp					
		9-24	wksab brn cl	fr ss sp	24"+				
		24+	wksab lt brn scl	fr ss sp					
4		0-19	SAB- RC	fi fr ss sp					.3-.35
		19-48	m.wksab- RCL	fr ss sp					
5									

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: ____
EVALUATED BY: ____ OTHER(S) PRESENT: ____
COMMENTS: ____